



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

September 29, 2017

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **9/21/17 7:30 am** and logged in under work order **7093695**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7093695-01
Name: HHS CENTER BLDG KIT SINK
Alias: #1 DRAW

Sampled: 09/20/17 06:20
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	09/27/17 16:39	KMC	EPA 200.8

Sample: 7093695-02
Name: HHS CENTER BLDG KIT SINK
Alias: #2 DRAW

Sampled: 09/20/17 06:20
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	09/27/17 16:40	KMC	EPA 200.8

Sample: 7093695-03
Name: BGS WEST HALL DF 1ST FL
Alias: #1 DRAW

Sampled: 09/20/17 07:30
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.68	ug/L		15	09/27/17 16:41	KMC	EPA 200.8

Sample: 7093695-04
Name: BGS WEST HALL DF 1ST FL
Alias: #2 DRAW

Sampled: 09/20/17 07:30
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.51	ug/L		15	09/27/17 16:42	KMC	EPA 200.8

Sample: 7093695-05
Name: LMS SOUTH OFFICE DF 1ST FL
Alias: #1 DRAW

Sampled: 09/20/17 07:13
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.41	ug/L		15	09/28/17 12:50	JMW	EPA 200.8



ANALYTICAL RESULTS

Sample: 7093695-06
Name: LMS SOUTH OFFICE DF 1ST FL
Alias: #2 DRAW

Sampled: 09/20/17 07:13
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.21	ug/L		15	09/28/17 12:51	JMW	EPA 200.8

Sample: 7093695-07
Name: LMS SOUTH SW HALL 2ND FL DF
Alias: #1 DRAW

Sampled: 09/20/17 07:17
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	7.48	ug/L		15	09/28/17 12:52	JMW	EPA 200.8

Sample: 7093695-08
Name: LMS SOUTH SW HALL 2ND FL DF
Alias: #2 DRAW

Sampled: 09/20/17 07:17
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.01	ug/L		15	09/28/17 12:53	JMW	EPA 200.8

Sample: 7093695-09
Name: LMS NORTH BIG GYM DF
Alias: #1 DRAW

Sampled: 09/20/17 07:05
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.35	ug/L		15	09/28/17 12:55	JMW	EPA 200.8

Sample: 7093695-10
Name: LMS NORTH BIG GYM DF
Alias: #2 DRAW

Sampled: 09/20/17 07:05
Received: 09/21/17 07:30
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	8.71	ug/L		15	09/28/17 12:56	JMW	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

** Indicates lab result exceeds a monitoring limit. Monitoring limits are either client permit limits or client requested action levels.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Janet Clutters For Kurt Stepping, Senior Project Manager



CHAIN OF CUSTODY RECORD

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615

PHONE # 800-752-6651
 FAX # 309-692-9689

IL

State where samples collected

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT) - (SAMPLE ACCEPTANCE POLICY ON REVERSE)

CLIENT		PROJECT NUMBER		P.O. NUMBER		MEANS SHIPPED		ANALYSIS REQUESTED		(FOR LAB USE ONLY)	
1	Herscher CUSD #2 501 N Main St Herscher, IL 60941 Larry Houbert	PHONE NUMBER 815/426-6868	FAX NUMBER 815/426-6869	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	DATE SHIPPED	DATE SHIPPED	LOGGED BY: 7093695-10 RPA	LAB PROJ. #
2		3		4		5		6		7	
SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	REMARKS	8		
Center B									Lead in Drinking Water		
HHS Center BLDG Kit Sink #1 Draw		9/20	6:20 AM	X		DW	1				
HHS Center BLDG Kit Sink #2 Draw		9/20	6:30 AM	X		DW	1				
BGS West Hall DF 1st Fl #1 Draw		9/20	7:30 AM	X		DW	1				
BGS West Hall DF 1st Fl #2 Draw		9/20	7:30 AM	X		DW	1				
LMS South Office DF 1st Fl #1 Draw		9/20	7:13 AM	X		DW	1				
LMS South Office DF 1st Fl #2 Draw		9/20	7:13 AM	X		DW	1				
LMS South SW Hall 2nd Fl DF #1 Draw		9/20	7:17 AM	X		DW	1				
LMS South SW Hall 2nd Fl DF #2 Draw		9/20	7:17 AM	X		DW	1				
LMS North Big Gym DF #1 Draw		9/20	7:05 AM	X		DW	1				
LMS North Big Gym DF #2 Draw		9/20	7:05 AM	X		DW	1				

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE)
 (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)
 RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE
 NORMAL

6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0. +6.0 C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.

7 RELINQUISHED BY (SIGNATURE)
 DATE TIME
 RECEIVED BY (SIGNATURE)
 DATE TIME
 RECEIVED AT LAB BY (SIGNATURE)
 DATE TIME

8 COMMENTS: (FOR LAB USE ONLY)
 SAMPLE TEMPERATURE UPON RECEIPT
 CHILL PROCESS STARTED PRIOR TO RECEIPT
 SAMPLE(S) RECEIVED ON ICE
 PROPER BOTTLES RECEIVED IN GOOD CONDITION
 BOTTLES FILLED WITH ADEQUATE VOLUME
 SAMPLES RECEIVED WITHIN HOLD TIME(S)
 (EXCLUDES TYPICAL FIELD PARAMETERS)
 DATE AND TIME TAKEN FROM SAMPLE BOTTLE
 26 °C
 Y OR N
 Y OR N
 Y OR N

Copies: white should accompany samples to PDC Labs. Yellow copy to be retained by the client.

PAGE _____ OF _____



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

March 31, 2017

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **3/17/17 9:40 am** and logged in under work order **7032556**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Kurt Stepping
Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7032556-01
Name: BGS KIT SINK #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 05:47
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.95	ug/L		03/27/17 10:36	03/27/17 13:01	KMC	EPA 200.8

Sample: 7032556-02
Name: BGS KIT SINK #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 05:47
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.00	ug/L		03/27/17 10:36	03/27/17 13:02	KMC	EPA 200.8

Sample: 7032556-03
Name: BGS WEST HALL #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 05:50
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.99	ug/L		03/27/17 10:36	03/27/17 13:50	KMC	EPA 200.8

Sample: 7032556-04
Name: BGS WEST HALL #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 05:50
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.82	ug/L		03/27/17 10:36	03/27/17 13:51	KMC	EPA 200.8

Sample: 7032556-05
Name: BGS EAST HALL 1ST FLR #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 05:53
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.73	ug/L		03/27/17 10:36	03/27/17 13:52	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7032556-06
Name: BGS EAST HALL 1ST FLR #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 05:53
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.77	ug/L		03/27/17 10:36	03/27/17 13:53	KMC	EPA 200.8

Sample: 7032556-07
Name: BGS NORTH HALL 1ST FLR #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:02
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.62	ug/L		03/27/17 10:36	03/27/17 13:54	KMC	EPA 200.8

Sample: 7032556-08
Name: BGS NORTH HALL 1ST FLR #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:02
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.63	ug/L		03/27/17 10:36	03/27/17 13:54	KMC	EPA 200.8

Sample: 7032556-09
Name: BGS EAST HALL 2ND FLR #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:07
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.48	ug/L		03/27/17 10:36	03/27/17 13:55	KMC	EPA 200.8

Sample: 7032556-10
Name: BGS EAST HALL 2ND FLR #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:07
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.93	ug/L		03/27/17 10:36	03/27/17 13:56	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7032556-11
Name: BGS NORTH HALL 2ND FLR #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:10
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		03/27/17 10:36	03/27/17 14:06	KMC	EPA 200.8

Sample: 7032556-12
Name: BGS NORTH HALL 2ND FLR #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:10
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.14	ug/L		03/27/17 10:36	03/27/17 14:07	KMC	EPA 200.8

Sample: 7032556-13
Name: BGS B208 #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:15
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.78	ug/L		03/27/17 10:36	03/27/17 14:08	KMC	EPA 200.8

Sample: 7032556-14
Name: BGS B208 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:15
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.51	ug/L		03/27/17 10:36	03/27/17 14:08	KMC	EPA 200.8

Sample: 7032556-15
Name: BGS B207 #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:18
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	11.5	ug/L		03/27/17 10:36	03/27/17 14:09	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7032556-16
Name: BGS B207 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:18
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.75	ug/L		03/27/17 10:36	03/27/17 14:10	KMC	EPA 200.8

Sample: 7032556-17
Name: BGS B202 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:22
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.35	ug/L		03/27/17 10:36	03/27/17 14:11	KMC	EPA 200.8

Sample: 7032556-18
Name: BGS B201 #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:25
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	47.7	ug/L		03/27/17 10:36	03/27/17 14:12	KMC	EPA 200.8

Sample: 7032556-19
Name: BGS B201 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:25
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.96	ug/L		03/27/17 10:36	03/27/17 14:22	KMC	EPA 200.8

Sample: 7032556-20
Name: BGS B200 #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:30
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	47.1	ug/L		03/27/17 10:36	03/27/17 14:22	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7032556-21
Name: BGS B200 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:30
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.54	ug/L		03/27/17 10:36	03/27/17 14:23	KMC	EPA 200.8

Sample: 7032556-22
Name: BGS B116 #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:35
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	14.6	ug/L		03/27/17 10:36	03/27/17 14:24	KMC	EPA 200.8

Sample: 7032556-23
Name: BGS B116 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:35
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.89	ug/L		03/27/17 10:36	03/27/17 14:25	KMC	EPA 200.8

Sample: 7032556-24
Name: BGS B115 #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:38
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	10.7	ug/L		03/27/17 10:36	03/27/17 14:26	KMC	EPA 200.8

Sample: 7032556-25
Name: BGS B115 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:38
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.35	ug/L		03/27/17 10:36	03/27/17 14:27	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7032556-26
Name: BGS B114 #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:43
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	18.4	ug/L		03/27/17 10:36	03/27/17 14:28	KMC	EPA 200.8

Sample: 7032556-27
Name: BGS B114 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:43
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.86	ug/L		03/27/17 10:36	03/27/17 14:36	KMC	EPA 200.8

Sample: 7032556-28
Name: BGS B113 #1 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:45
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	9.84	ug/L		03/27/17 10:36	03/27/17 14:38	KMC	EPA 200.8

Sample: 7032556-29
Name: BGS B113 #2 DRAW
Matrix: Drinking Water - Grab

Sampled: 03/16/17 06:45
Received: 03/17/17 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.55	ug/L		03/27/17 10:36	03/27/17 14:39	KMC	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

Certifications

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615




PHONE # 800-752-6651
 FAX # 309-692-9689

CHAIN OF CUSTODY RECORD

State where samples collected

IL

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT) - (SAMPLE ACCEPTANCE POLICY ON REVERSE)

CLIENT 1 Herxhe CUSD #2 ADDRESS 501 N. Main St CITY Herscher, IL 60961 STATE ZIP CONTACT PERSON Larry Houberg			PROJECT NUMBER 815/426-6868 P.O. NUMBER 85/426-6869 PHONE NUMBER 815/426-6868 FAX NUMBER 815/426-6869 SAMPLER (PLEASE PRINT) Larry Houberg SIGNATURE 		MEANS SHIPPED UPS DATE SHIPPED 3/16/17 MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-SOLID LCHT-LEACHATE OTHER:		ANALYSIS REQUESTED 3 Lead in Drinking Water		(FOR LAB USE ONLY) 4 LOGIN # 7032556-29 LOGGED BY: R LAB PROJ. # TEMPLATE: PROJ. MGR.:	
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT			DATE COLLECTED TIME COLLECTED RUSH DATE RESULTS NEEDED (NORMAL)		MATRIX TYPE BOTTLE COUNT		REMARKS			
BGS Kit Sink #1 Draw			3/16 5:47 AM X		DW 1		X			
BGS Kit Sink #2 Draw			3/16 5:47 AM X		DW 1		X			
BGS West Hall #1 Draw			3/16 5:50 AM X		DW 1		X			
BGS West Hall #2 Draw			3/16 5:50 AM X		DW 1		X			
BGS East Hall 1st fl #1 Draw			3/16 5:53 AM X		DW 1		X			
BGS East Hall 1st fl #2 Draw			3/16 5:53 AM X		DW 1		X			
BGS North Hall 1st fl #1 Draw			3/16 6:02 AM X		DW 1		X			
BGS North Hall 1st fl #2 Draw			3/16 6:02 AM X		DW 1		X			
BGS East Hall 2nd fl #1 Draw			3/16 6:07 AM X		DW 1		X			
BGS East Hall 2nd fl #2 Draw			3/16 6:07 AM X		DW 1		X			
BGS North Hall 2nd fl #1 Draw			3/16 6:10 AM X		DW 1		X			
BGS North Hall 2nd fl #2 Draw			3/16 6:10 AM X		DW 1		X			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX			DATE COLLECTED TIME COLLECTED RUSH DATE RESULTS NEEDED (EMAIL)		MATRIX TYPE BOTTLE COUNT		6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0 C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.			
7 RELINQUISHED BY (SIGNATURE) 			RECEIVED BY: (SIGNATURE) 		COMMENTS: (FOR LAB USE ONLY) 8 SAMPLE TEMPERATURE UPON RECEIPT CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE		DATE TIME DATE TIME DATE TIME DATE TIME DATE TIME DATE TIME			

Copies: white should accompany samples to PDC Labs. Yellow copy to be retained by the client.

CHAIN OF CUSTODY RECORD

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615

PHONE # 800-752-6651
 FAX # 309-692-9689

State where samples collected

IL

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT) - (SAMPLE ACCEPTANCE POLICY ON REVERSE)

1 CLIENT		PROJECT NUMBER		P.O. NUMBER		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
Herscher Casa #2		815/426-6868		815/426-6869		UPS				LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: _____	
501 N. Main St		PHONE NUMBER		FAX NUMBER		DATE SHIPPED					
Herscher, IL 60941		815/426-6868		815/426-6869		3/16/17					
Larry Hoberg		SAMPLER (PLEASE PRINT)		SAMPLER'S SIGNATURE		MATRIX TYPES:					
Larry Hoberg		Larry Hoberg		Larry Hoberg		WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-SOLID LOHT-LEACHATE OTHER: _____					
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE	GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	REMARKS		
BGS B208 #1 Draw		3/16	6:15Am		X		DW	1	X	Lead in drinking water	
BGS B208 #2 Draw		3/16	6:15Am		X		DW	1	X		
BGS B207 #1 Draw		3/16	6:18Am		X		DW	1	X		
BGS B207 #2 Draw		3/16	6:18Am		X		DW	1	X		
BGS B202 #1 Draw		3/16	6:21Am		X		DW	1	X		
BGS B202 #2 Draw		3/16	6:28Am		X		DW	1	X		
BGS B201 #1 Draw		3/16	6:25Am		X		DW	1	X		
BGS B201 #2 Draw		3/16	6:25Am		X		DW	1	X		
BGS B200 #1 Draw		3/16	6:30Am		X		DW	1	X		
BGS B200 #2 Draw		3/16	6:30Am		X		DW	1	X		
BGS B116 #1 Draw		3/16	6:35Am		X		DW	1	X		
BGS B116 #2 Draw		3/16	6:35Am		X		DW	1	X		
6		DATE RESULTS NEEDED		DATE RESULTS NEEDED		E-MAIL					
5		TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH FEE IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		RUSH		PHONE					
		NORMAL									
7		RELINQUISHED BY: (SIGNATURE)		RECEIVED BY: (SIGNATURE)		DATE				8	
Larry Hoberg		Larry Hoberg		Larry Hoberg		3/16/17				COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT: _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT: _____ SAMPLE(S) RECEIVED ON ICE: _____ PROPER BOTTLES RECEIVED IN GOOD CONDITION: _____ BOTTLES FILLED WITH CORRECT VOLUME: _____ SAMPLES RECEIVED WITH HOLD TIME(S): _____ (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE: _____	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE					
		3/16/17		Larry Hoberg		3/16					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED AT LAB BY: (SIGNATURE)		DATE					
		3/16		Larry Hoberg		3/16					

Copies: white should accompany samples to PDC Labs. Yellow copy to be retained by the client.

CHAIN OF CUSTODY RECORD

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615

PHONE # 800-752-6651
 FAX # 309-692-9689

State where samples collected

IL

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT) - (SAMPLE ACCEPTANCE POLICY ON REVERSE)

1 CLIENT		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)		
Hertscher CUSD #2 501 N Main St Hertscher, IL 60941 Larry Houborg		ANALYSIS REQUESTED Lead in drinking water		LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR: _____		
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		P.O. NUMBER		MEANS SHIPPED		
PROJECT NUMBER	PHONE NUMBER	FAX NUMBER	DATE SHIPPED	MATRIX TYPE	BOTTLE COUNT	
DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE	GRAB	COMP		
BGS B115 #1	Draw	3/16	6:38AM	X	DW	1
BGS B115 #2	Draw	3/16	6:38AM	X	DW	1
BGS B114 #1	Draw	3/16	6:43AM	X	DW	1
BGS B114 #2	Draw	3/16	6:43AM	X	DW	1
BGS B113 #1	Draw	3/16	6:45AM	X	DW	1
BGS B113 #2	Draw	3/16	6:45AM	X	DW	1
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) NORMAL (E-MAIL)						
6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.						
7 RELINQUISHED BY (SIGNATURE)		8 COMMENTS (FOR LAB USE ONLY)				
Larry Houborg RECEIVED AT LAB BY: (SIGNATURE)		SAMPLE TEMPERATURE UPON RECEIPT CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE		DATE: 3/16/17 TIME: 8:40 AM		

Copies: white should accompany samples to PDC Labs. Yellow copy to be retained by the client.



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

March 31, 2017

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **3/23/17 7:10 am** and logged in under work order **7033082**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Kurt Stepping
Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7033082-01
Name: BGS 1ST FL
Alias: B111 FIRST DRAW

Sampled: 03/22/17 06:43
Received: 03/23/17 07:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	16.7	ug/L		03/31/17 09:03	03/31/17 09:24	KMC	EPA 200.8

Sample: 7033082-02
Name: BGS 1ST FL
Alias: B111 SECOND DRAW

Sampled: 03/22/17 06:43
Received: 03/23/17 07:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.65	ug/L		03/31/17 09:03	03/31/17 09:25	KMC	EPA 200.8

Sample: 7033082-03
Name: BGS 1ST FL
Alias: B108 FIRST DRAW

Sampled: 03/22/17 06:50
Received: 03/23/17 07:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	42.7	ug/L		03/31/17 09:03	03/31/17 09:27	KMC	EPA 200.8

Sample: 7033082-04
Name: BGS 1ST FL
Alias: B108 SECOND DRAW

Sampled: 03/22/17 06:50
Received: 03/23/17 07:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.38	ug/L		03/31/17 09:03	03/31/17 09:28	KMC	EPA 200.8

Sample: 7033082-05
Name: BGS 1ST FL
Alias: B107 FIRST DRAW

Sampled: 03/22/17 06:54
Received: 03/23/17 07:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	174	ug/L		03/31/17 09:03	03/31/17 09:29	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7033082-06
Name: BGS 1ST FL
Alias: B107 SECOND DRAW

Sampled: 03/22/17 06:54
Received: 03/23/17 07:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	8.64	ug/L		03/31/17 09:03	03/31/17 09:30	KMC	EPA 200.8

Sample: 7033082-07
Name: BGS 1ST FL
Alias: B106 FIRST DRAW

Sampled: 03/22/17 07:00
Received: 03/23/17 07:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	19.3	ug/L		03/31/17 09:03	03/31/17 09:40	KMC	EPA 200.8

Sample: 7033082-08
Name: BGS 1ST FL
Alias: B106 SECOND DRAW

Sampled: 03/22/17 07:00
Received: 03/23/17 07:10
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.47	ug/L		03/31/17 09:03	03/31/17 09:42	KMC	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

Certifications

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



CHAIN OF CUSTODY RECORD

PDC LABORATORIES, INC.
2231 WEST ALTORFER DRIVE
PEORIA, IL 61615

PHONE # 800-752-6651
FAX # 309-692-9689

State where samples collected IL

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT) - (SAMPLE ACCEPTANCE POLICY ON REVERSE)

1 CLIENT: <u>Herscher CUSA #2</u> ADDRESS: <u>501 N Main St</u> CITY: <u>Peoria</u> STATE: <u>IL</u> ZIP: <u>61604</u> CONTACT PERSON: <u>Larry Hoberg</u>		PROJECT NUMBER: _____ P.O. NUMBER: _____ PHONE NUMBER: <u>815/426-6868</u> FAX NUMBER: <u>815/426-6869</u>		MEANS SHIPPED: _____ DATE SHIPPED: <u>3/22/17</u> MATRIX TYPES: WW-WASTEWATER _____ DW-DRINKING WATER _____ GW-GROUND WATER _____ MS-SOLID WASTE _____ LS-LEACHATE _____ OTHER: _____		ANALYSIS REQUESTED: _____ LOGIN #: <u>7033082-8</u> LOGGED BY: <u>6994</u> LAB PROJ. #: _____ TEMPLATE: _____ PROJ. MGR.: _____			
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE	GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	REMARKS
BGS 1st St / B111 1st Draw		3/22	6:45 AM	DW	X		DW	1	X Lead in Drinking Water
BGS 1st St / B111 2nd Draw		3/22	6:43 AM	DW	X		DW	1	X
BGS 1st St / B108 1st Draw		3/22	6:50 AM	DW	X		DW	1	X
BGS 1st St / B108 2nd Draw		3/22	6:50 AM	DW	X		DW	1	X
BGS 1st St / B107 1st Draw		3/22	6:54 AM	DW	X		DW	1	X
BGS 1st St / B107 2nd Draw		3/22	6:54 AM	DW	X		DW	1	X
BGS 1st St / B106 1st Draw		3/22	7:00 AM	DW	X		DW	1	X
BGS 1st St / B106 2nd Draw		3/22	7:00 AM	DW	X		DW	1	X
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX _____ PHONE _____ EMAIL ADDRESS _____ FAX # _____ PHONE # _____		RUSH: <u>NORMAL</u> DATE RESULTS NEEDED: _____ E-MAIL: _____		6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.					
7 RELINQUISHED BY: (SIGNATURE) <u>Larry Hoberg</u> DATE: <u>3/22/17</u> TIME: <u>10:30 AM</u>		RECEIVED BY: (SIGNATURE) <u>Arndt</u> DATE: _____ TIME: _____		RECEIVED BY: (SIGNATURE) <u>Arndt</u> DATE: _____ TIME: _____		RECEIVED AT LAB BY: (SIGNATURE) <u>Arndt</u> DATE: <u>3/27/17</u> TIME: <u>7:10</u>		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT: _____ °C CHILL PROCESS STARTED PRIOR TO RECEIPT: _____ SAMPLE(S) RECEIVED ON ICE: _____ PROPER BOTTLES RECEIVED IN GOOD CONDITION: _____ BOTTLES FILLED WITH ADEQUATE VOLUME: _____ SAMPLES RECEIVED WITHIN HOLD TIME(S): _____ (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE: _____	



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

April 14, 2017

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **4/6/17 7:40 am** and logged in under work order **7040917**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Kurt Stepping
Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7040917-01
Name: CENTER BLDG NORTH HALL 1ST FL
Alias: 1ST DRAW

Sampled: 04/05/17 04:45
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.36	ug/L		15	04/14/17 11:37	KMC	EPA 200.8

Sample: 7040917-02
Name: CENTER BLDG NORTH HALL 1ST FL
Alias: 2ND DRAW

Sampled: 04/05/17 04:45
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.83	ug/L		15	04/14/17 11:38	KMC	EPA 200.8

Sample: 7040917-03
Name: CENTER BLDG CAFE HALL 1ST FL
Alias: 1ST DRAW

Sampled: 04/05/17 04:50
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 11:39	KMC	EPA 200.8

Sample: 7040917-04
Name: CENTER BLDG CAFE HALL 1ST FL
Alias: 2ND DRAW

Sampled: 04/05/17 04:50
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 11:40	KMC	EPA 200.8

Sample: 7040917-05
Name: CENTER BLDG KIT SINK
Alias: 1ST DRAW

Sampled: 04/05/17 05:00
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	9.06	ug/L		15	04/14/17 11:41	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-06
Name: CENTER BLDG KIT SINK
Alias: 2ND DRAW

Sampled: 04/05/17 05:00
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 11:42	KMC	EPA 200.8

Sample: 7040917-07
Name: CENTER BLDG HALL 2ND FL
Alias: 1ST DRAW

Sampled: 04/05/17 07:15
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 11:43	KMC	EPA 200.8

Sample: 7040917-08
Name: CENTER BLDG HALL 2ND FL
Alias: 2ND DRAW

Sampled: 04/05/17 07:15
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 11:44	KMC	EPA 200.8

Sample: 7040917-09
Name: EAST HALL DF 1ST FL
Alias: 1ST DRAW

Sampled: 04/05/17 05:09
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 11:52	KMC	EPA 200.8

Sample: 7040917-10
Name: EAST HALL DF 1ST FL
Alias: 2ND DRAW

Sampled: 04/05/17 05:09
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 11:53	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-11
Name: RM G106
Alias: 1ST DRAW

Sampled: 04/05/17 05:15
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	20.7	ug/L		**15	04/14/17 11:54	KMC	EPA 200.8

Sample: 7040917-12
Name: RM G106
Alias: 2ND DRAW

Sampled: 04/05/17 05:15
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.12	ug/L		15	04/14/17 11:54	KMC	EPA 200.8

Sample: 7040917-13
Name: RM G107
Alias: 1ST DRAW

Sampled: 04/05/17 05:20
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	32.8	ug/L		**15	04/14/17 11:55	KMC	EPA 200.8

Sample: 7040917-14
Name: RM G107
Alias: 2ND DRAW

Sampled: 04/05/17 05:20
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.52	ug/L		15	04/14/17 11:56	KMC	EPA 200.8

Sample: 7040917-15
Name: RM G108
Alias: 1ST DRAW

Sampled: 04/05/17 05:30
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	22.0	ug/L		**15	04/14/17 11:57	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-16
Name: RM G108
Alias: 2ND DRAW

Sampled: 04/05/17 05:30
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.38	ug/L		15	04/14/17 11:58	KMC	EPA 200.8

Sample: 7040917-17
Name: RM G109
Alias: 1ST DRAW

Sampled: 04/05/17 05:35
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	29.4	ug/L		**15	04/14/17 12:06	KMC	EPA 200.8

Sample: 7040917-18
Name: RM G109
Alias: 2ND DRAW

Sampled: 04/05/17 05:35
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.36	ug/L		15	04/14/17 12:07	KMC	EPA 200.8

Sample: 7040917-19
Name: RM G114
Alias: 1ST DRAW

Sampled: 04/05/17 05:40
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	103	ug/L		**15	04/14/17 12:08	KMC	EPA 200.8

Sample: 7040917-20
Name: RM G114
Alias: 2ND DRAW

Sampled: 04/05/17 05:40
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.61	ug/L		15	04/14/17 12:09	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-21
Name: RM G116
Alias: 1ST DRAW

Sampled: 04/05/17 05:45
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	30.8	ug/L		**15	04/14/17 12:10	KMC	EPA 200.8

Sample: 7040917-22
Name: RM G116
Alias: 2ND DRAW

Sampled: 04/05/17 05:45
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.81	ug/L		15	04/14/17 12:11	KMC	EPA 200.8

Sample: 7040917-23
Name: RM G117
Alias: 1ST DRAW

Sampled: 04/05/17 05:50
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	24.2	ug/L		**15	04/14/17 12:11	KMC	EPA 200.8

Sample: 7040917-24
Name: RM G121
Alias: 1ST DRAW

Sampled: 04/05/17 06:00
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	26.0	ug/L		**15	04/14/17 12:12	KMC	EPA 200.8

Sample: 7040917-25
Name: RM G117
Alias: 2ND DRAW

Sampled: 04/05/17 05:50
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.18	ug/L		15	04/14/17 12:20	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-26
Name: RM G121
Alias: 2ND DRAW

Sampled: 04/05/17 06:00
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.50	ug/L		15	04/14/17 12:21	KMC	EPA 200.8

Sample: 7040917-27
Name: RM G122
Alias: 1ST DRAW

Sampled: 04/05/17 06:10
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	13.4	ug/L		15	04/14/17 12:22	KMC	EPA 200.8

Sample: 7040917-28
Name: RM G122
Alias: 2ND DRAW

Sampled: 04/05/17 06:10
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.13	ug/L		15	04/14/17 12:23	KMC	EPA 200.8

Sample: 7040917-29
Name: NORTH HALL DF 1ST FL
Alias: 1ST DRAW

Sampled: 04/05/17 05:55
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:24	KMC	EPA 200.8

Sample: 7040917-30
Name: NORTH HALL DF 1ST FL
Alias: 2ND DRAW

Sampled: 04/05/17 05:55
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:25	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-31
Name: SOUTH HALL DF 1ST FL
Alias: 1ST DRAW

Sampled: 04/05/17 05:25
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.14	ug/L		15	04/14/17 12:26	KMC	EPA 200.8

Sample: 7040917-32
Name: SOUTH HALL DF 1ST FL
Alias: 2ND DRAW

Sampled: 04/05/17 05:25
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:27	KMC	EPA 200.8

Sample: 7040917-33
Name: NORTH HALL LIB DF 1ST FL
Alias: 1ST DRAW

Sampled: 04/05/17 06:03
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:35	KMC	EPA 200.8

Sample: 7040917-34
Name: NORTH HALL LIB DF 1ST FL
Alias: 2ND DRAW

Sampled: 04/05/17 06:03
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:35	KMC	EPA 200.8

Sample: 7040917-35
Name: SOUTH HALL DF 2ND FL
Alias: 1ST DRAW

Sampled: 04/05/17 07:05
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:36	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-36
Name: SOUTH HALL DF 2ND FL
Alias: 2ND DRAW

Sampled: 04/05/17 07:05
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.01	ug/L		15	04/14/17 12:37	KMC	EPA 200.8

Sample: 7040917-37
Name: G200 2ND FL
Alias: 1ST DRAW

Sampled: 04/05/17 06:20
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	7.24	ug/L		15	04/14/17 12:38	KMC	EPA 200.8

Sample: 7040917-38
Name: G200 2ND FL
Alias: 2ND DRAW

Sampled: 04/05/17 06:20
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:39	KMC	EPA 200.8

Sample: 7040917-39
Name: NORTH HALL LIB DF 2ND FL
Alias: 1ST DRAW

Sampled: 04/05/17 06:25
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:40	KMC	EPA 200.8

Sample: 7040917-40
Name: NORTH HALL LIB DF 2ND FL
Alias: 2ND DRAW

Sampled: 04/05/17 06:25
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:41	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-41
Name: NORTH HALL DF 2ND FL
Alias: 1ST DRAW

Sampled: 04/05/17 06:30
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 12:49	KMC	EPA 200.8

Sample: 7040917-42
Name: NORTH HALL DF 2ND FL
Alias: 2ND DRAW

Sampled: 04/05/17 06:30
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.33	ug/L		15	04/14/17 12:50	KMC	EPA 200.8

Sample: 7040917-43
Name: G217
Alias: 1ST DRAW

Sampled: 04/05/17 06:35
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	58.3	ug/L		**15	04/14/17 12:51	KMC	EPA 200.8

Sample: 7040917-44
Name: G217
Alias: 2ND DRAW

Sampled: 04/05/17 06:35
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.66	ug/L		15	04/14/17 12:52	KMC	EPA 200.8

Sample: 7040917-45
Name: G216
Alias: 1ST DRAW

Sampled: 04/05/17 06:40
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	25.5	ug/L		**15	04/14/17 12:52	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-46
Name: G216
Alias: 2ND DRAW

Sampled: 04/05/17 06:40
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.56	ug/L		15	04/14/17 12:53	KMC	EPA 200.8

Sample: 7040917-47
Name: G215 #1
Alias: 1ST DRAW

Sampled: 04/05/17 06:42
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	91.8	ug/L		**15	04/14/17 12:54	KMC	EPA 200.8

Sample: 7040917-48
Name: G215 #1
Alias: 2ND DRAW

Sampled: 04/05/17 06:42
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	13.7	ug/L		15	04/14/17 12:55	KMC	EPA 200.8

Sample: 7040917-49
Name: G215 #3
Alias: 1ST DRAW

Sampled: 04/05/17 06:48
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	195	ug/L		**15	04/14/17 13:06	KMC	EPA 200.8

Sample: 7040917-50
Name: G215 #3
Alias: 2ND DRAW

Sampled: 04/05/17 06:48
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	7.25	ug/L		15	04/14/17 13:07	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7040917-51
Name: G215 #4
Alias: 1ST DRAW

Sampled: 04/05/17 06:50
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	163	ug/L		**15	04/14/17 13:08	KMC	EPA 200.8

Sample: 7040917-52
Name: G215 #4
Alias: 2ND DRAW

Sampled: 04/05/17 06:50
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	7.62	ug/L		15	04/14/17 13:09	KMC	EPA 200.8

Sample: 7040917-53
Name: G210 TL
Alias: 1ST DRAW

Sampled: 04/05/17 07:10
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.75	ug/L		15	04/14/17 13:10	KMC	EPA 200.8

Sample: 7040917-54
Name: G210 TL
Alias: 2ND DRAW

Sampled: 04/05/17 07:10
Received: 04/06/17 07:40
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	04/14/17 13:10	KMC	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

** Indicates lab result exceeds a monitoring limit. Monitoring limits are either client permit limits or client requested action levels.

Certifications

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Janet Clutters For Kurt Stepping, Senior Project Manager



PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 762-6661 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
ILLINOIS SCHOOLS LEAD TESTING

191

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT		P.O. NUMBER		SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
Herscher CUSD # 2/HHS		85/426-6868		Center Bldg North Hall		DATE SHIPPED		LEAD 200.8		LOGIN # 704091754	
501 N Main St		SAMPLER (PLEASE PRINT)		EMAIL		DATE SHIPPED				LOGGED BY: <i>[Signature]</i>	
Herscher, IL 60941		Larry Houbert		Larry Houbert		MATRIX TYPES:				LAB PROJ. #	
Larry Houbert		SAMPLER SIGNATURE		Larry Houbert		WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LGT- LEACHATE				TEMPLATE:	
2 SAMPLE DESCRIPTION AND WATER TESTED		DATE SAMPLE COLLECTED		TIME SAMPLE COLLECTED		OTHER:				PROJ. MGR.: KURT STEPPING	
Center Bldg North Hall / 1st fl / 1st draw		4/5		4:45 AM		MTR				DATE/TIME LAST USED	
Center Bldg North Hall / 1st fl / 2nd draw		4/5		4:45 AM		DW		1			
Center Bldg Cate Hall / 1st fl / 1st draw		4/5		4:50 AM		DW		1			
Center Bldg Cate Hall / 1st fl / 2nd draw		4/5		7:50 AM		DW		1			
Center Bldg / Kitsink / 1st draw		4/5		5:00 AM		DW		1			
Center Bldg / Kitsink / 2nd draw		4/5		5:00 AM		DW		1			
Center Bldg Hall / 2nd fl / 1st draw		4/5		7:15 AM		DW		1			
Center Bldg Hall / 2nd fl / 2nd draw		4/5		7:15 AM		DW		1			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH FEE IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		6		The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0° C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.	
NORMAL		4/5		[Signature]		DATE					
7 RELINQUISHED BY: (SIGNATURE)		TIME		RECEIVED BY: (SIGNATURE)		DATE		8		COMMENTS: (FOR LAB USE ONLY)	
[Signature]		8:00 AM		[Signature]		DATE				SAMPLE TEMPERATURE UPON RECEIPT 15°C	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE				CHILL PROCESS STARTED PRIOR TO RECEIPT	
[Signature]		DATE		[Signature]		DATE				SAMPLE(S) RECEIVED ON ICE	
		TIME		[Signature]		DATE				PROPER BOTTLES RECEIVED IN GOOD CONDITION	
		DATE		[Signature]		DATE				BOTTLES FILLED WITH ADEQUATE VOLUME	
		TIME		[Signature]		DATE				SAMPLES RECEIVED WITHIN HOLD TIME(S)	
		DATE		[Signature]		DATE				(EXCLUDES TYPICAL FIELD PARAMETERS)	
		TIME		[Signature]		DATE				DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

Ry 2

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT		P.O. NUMBER		SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
Herscher CUSD #02/HIS		815/426-6888		Herscher, IL 60941		DATE SHIPPED		LEAD 200.8		LOGIN #	
ADDRESS 501 N. Main St		PHONE NUMBER		EMAIL		DATE SHIPPED				LOGGED BY:	
CITY STATE ZIP Herscher, IL 60941		SAMPLER (PLEASE PRINT)		SAMPLER'S SIGNATURE		MATRIX TYPES: W-W WASTEWATER D-W DRINKING WATER U-W CUPPED WATER M-S MASH L-C LEACHATE OTHER:				LAB PROJ. #	
CONTACT PERSON Larry Houborg		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED				TEMPLATE:	
2 SAMPLES ANALYZED		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED				PROJ. MGR.: KURT STEPPING	
East Hall DF/1st/1st draw	4/5	5:09 AM	ml	DW	1	X					DATE/TIME LAST USED
East Hall DF/1st/1st / 2nd draw	4/5	5:09 AM	ml	DW	1	X					
Rm G106 / 1st draw	4/5	5:15 AM	ml	DW	1	X					
Rm G106 / 2nd draw	4/5	5:15 AM	ml	DW	1	X					
Rm G107 / 1st draw	4/5	5:20 AM	ml	DW	1	X					
Rm G107 / 2nd draw	4/5	5:20 AM	ml	DW	1	X					
Rm G108 / 1st draw	4/5	5:20 AM	ml	DW	1	X					
Rm G108 / 2nd draw	4/5	5:20 AM	ml	DW	1	X					
Rm G109 / 1st draw	4/5	5:35 AM	ml	DW	1	X					
Rm G109 / 2nd draw	4/5	5:35 AM	ml	DW	1	X					

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
 (RUSH THAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)

6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.

7 RELINQUISHED BY: (SIGNATURE) *Larry Houborg* DATE *4/5* TIME *8:00 AM*

8 COMMENTS: (FOR LAB USE ONLY)

RECEIVED BY: (SIGNATURE) *AGH* DATE *4/6/17* TIME *2:40*

RECEIVED BY: (SIGNATURE) DATE TIME

RECEIVED BY: (SIGNATURE) DATE TIME

RECEIVED BY: (SIGNATURE) DATE TIME

RECEIVED BY: (SIGNATURE) DATE TIME

9 SAMPLE TEMPERATURE UPON RECEIPT *13 °C*

CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N

SAMPLE(S) RECEIVED ON ICE Y OR N

PROPER BOTTLES RECEIVED IN GOOD CONDITION Y OR N

BOTTLES FILLED WITH ADEQUATE VOLUME Y OR N

SAMPLES RECEIVED WITHIN HOLD TIME(S) Y OR N

(EXCLUDES TYPICAL FIELD PARAMETERS)

DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

pg 3

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: <u>Herscher CUSD #2 / HHS</u> ADDRESS: <u>501 N Main St</u> CITY: <u>Peoria, IL</u> STATE: <u>IL</u> ZIP: <u>60941</u> CONTACT PERSON: <u>Larry Humberg</u>		SCHOOL NAME: _____ EMAIL: _____		3 ANALYSIS REQUESTED: <u>LEAD 200.8</u>		4 (FOR LAB USE ONLY) LOGIN #: _____ LAB PROJ. #: _____ TEMPLATE: _____ PROJ. MGR.: <u>KURT STEPPING</u>	
2 SAMPLE DESCRIPTION AS CONTAINED ON REQUEST FORM: <u>G-114 / 1st draw</u> <u>G-114 / 2nd draw</u> <u>G-116 / 1st draw</u> <u>G-116 / 2nd draw</u> <u>G-117 / 1st draw</u> <u>G-121 / 1st draw</u> <u>G-117 / 2nd draw</u> <u>G-121 / 2nd draw</u> <u>G-122 / 1st draw</u> <u>G-122 / 2nd draw</u>		P.O. NUMBER: _____ PHONE NUMBER: <u>8157426688</u> SAMPLER (PLEASE PRINT): <u>Larry Humberg</u> SAMPLER'S SIGNATURE: <u>[Signature]</u>		MEANS SHIPPED: _____ DATE SHIPPED: _____ MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER: _____		DATE/TIME LAST USED: _____	
6 TURNAROUND TIME REQUESTED (PLEASE CIRCLE): <u>NORMAL</u> (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____		DATE RESULTS NEEDED: _____ RUSH: _____ DATE: _____ TIME: _____		6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT: <u>13</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE	
7 RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u>		RECEIVED BY: (SIGNATURE) <u>[Signature]</u>		DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: <u>4/17</u> TIME: <u>8:00 AM</u> DATE: _____ TIME: _____		7 RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u>	

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

194

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Herscher CUSD #22 / HIS		P.O. NUMBER		SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
ADDRESS 501 N Main St		PHONE NUMBER 815/426-6888		EMAIL		DATE SHIPPED		LEAD 2008		LOGIN #	
CITY Herscher, IL 60941		SAMPLER (PLEASE PRINT) Larry Houbert		SCHOOL NAME		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE				LOGGED BY:	
STATE IL		SAMPLER'S SIGNATURE Larry Houbert		SCHOOL NAME		OTHER:				LAB PROJ. #	
CONTACT PERSON Larry Houbert		SAMPLER'S SIGNATURE Larry Houbert		SCHOOL NAME		DATE				TEMPLATE:	
2		SAMPLER'S SIGNATURE Larry Houbert		SCHOOL NAME		DATE				PROJ. MGR.: KURT STEPPING	
North Hall DF / 1st fl / 1st draw		4/5		5:55 AM		ml		DW		1	
North Hall DF / 1st fl / 2nd draw		4/5		5:55 AM		ml		DW		1	
South Hall DF / 1st fl / 1st draw		4/5		5:25 AM		ml		DW		1	
South Hall DF / 1st fl / 2nd draw		4/5		5:25 AM		ml		DW		1	
North Hall LJBDF / 1st fl / 1st draw		4/5		6:03 AM		ml		DW		1	
North Hall LJBDF / 1st fl / 2nd draw		4/5		6:03 AM		ml		DW		1	
South Hall DF / 1st fl / 1st draw		4/5		5:25 AM		ml		DW		1	
South Hall DF / 2nd fl / 2nd draw		4/5		5:25 AM		ml		DW		1	
G200 / 2nd fl / 1st draw		4/5		6:20 AM		ml		DW		1	
G200 / 2nd fl / 2nd draw		4/5		6:20 AM		ml		DW		1	
5		TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH		DATE RESULTS NEEDED						DATE/TIME LAST USED	
RUSH RESULTS VIA (PLEASE CIRCLE) PHONE FAX PHONE		PHONE # IF DIFFERENT FROM ABOVE:									
7		RELINQUISHED BY (SIGNATURE) Larry Houbert		RECEIVED BY (SIGNATURE) GPH		DATE 4/5		DATE 4/6/17		8	
RELINQUISHED BY (SIGNATURE)		DATE 8:00 AM		RECEIVED BY (SIGNATURE)		DATE		DATE		SAMPLE TEMPERATURE UPON RECEIPT	
RELINQUISHED BY (SIGNATURE)		DATE		RECEIVED BY (SIGNATURE)		DATE		DATE		13 °C	
RELINQUISHED BY (SIGNATURE)		DATE		RECEIVED BY (SIGNATURE)		DATE		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT	
RELINQUISHED BY (SIGNATURE)		DATE		RECEIVED BY (SIGNATURE)		DATE		DATE		SAMPLE(S) RECEIVED ON ICE	
RELINQUISHED BY (SIGNATURE)		DATE		RECEIVED BY (SIGNATURE)		DATE		DATE		PROPER BOTTLES RECEIVED IN GOOD CONDITION	
RELINQUISHED BY (SIGNATURE)		DATE		RECEIVED BY (SIGNATURE)		DATE		DATE		BOTTLES FILLED WITH ADEQUATE VOLUME	
RELINQUISHED BY (SIGNATURE)		DATE		RECEIVED BY (SIGNATURE)		DATE		DATE		SAMPLES RECEIVED WITHIN HOLD TIME(S)	
RELINQUISHED BY (SIGNATURE)		DATE		RECEIVED BY (SIGNATURE)		DATE		DATE		(EXCLUDES TYPICAL FIELD PARAMETERS)	
RELINQUISHED BY (SIGNATURE)		DATE		RECEIVED BY (SIGNATURE)		DATE		DATE		DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

6 The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0-1.6 °C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.

8 COMMENTS: (FOR LAB USE ONLY)
 Time on bottles say 7:05 a.m. RPH

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
ILLINOIS SCHOOLS LEAD TESTING

195

1 CLIENT		P.O. NUMBER		SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
Herscher CUSD #12 / HFS		815/426-6968		Herscher IL 60941		DATE SHIPPED		LEAD 200.8		LOGIN #	
501 N Main St.		SAMPLER (PLEASE PRINT)		EMAIL		MATRIX TYPES:				LOGGED BY:	
Herscher IL 60941		Larry Houberg		Larry Houberg		WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE				LAB PROJ. #	
CONTACT PERSON		SAMPLER'S SIGNATURE		SAMPLER'S SIGNATURE		OTHER:				TEMPLATE:	
Larry Houberg		Larry Houberg		Larry Houberg						PROJ. MGR.: KURT STEPPING	
2		DATE COLLECTED		TIME COLLECTED		DATE SHIPPED		DATE TIME LAST USED			
North Hall LIBDF / 2nd fl / 1st draw	4/5	6:25 AM	mi	DW	1	X					
North Hall LIBDF / 2nd fl / 2nd draw	4/5	6:25 PM	mi	DW	1	X					
North Hall DF / 2nd fl / 1st draw	4/5	6:30 AM	mi	DW	1	X					
North Hall DF / 2nd fl / 2nd draw	4/5	6:30 AM	mi	DW	1	X					
G217 / 1st draw	4/5	6:35 AM	mi	DW	1	X					
G217 / 2nd draw	4/5	6:35 AM	mi	DW	1	X					
G216 / 1st draw	4/5	6:40 AM	mi	DW	1	X					
G216 / 2nd draw	4/5	6:40 AM	mi	DW	1	X					
G216 / 1st draw	4/5	6:40 AM	mi	DW	1	X					
G216 / 2nd draw	4/5	6:40 AM	mi	DW	1	X					

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
 (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)

6 DATE RESULTS NEEDED

7 RELINQUISHED BY: (SIGNATURE) DATE 4/5 TIME 8:00 AM
 RELINQUISHED BY: (SIGNATURE) DATE TIME
 RELINQUISHED BY: (SIGNATURE) DATE TIME

8 COMMENTS: (FOR LAB USE ONLY)
 SAMPLE TEMPERATURE UPON RECEIPT 13 °C
 CHILL PROCESS STARTED PRIOR TO RECEIPT
 SAMPLE(S) RECEIVED ON ICE
 PROPER BOTTLES RECEIVED IN GOOD CONDITION
 BOTTLES FILLED WITH ADEQUATE VOLUME
 SAMPLES RECEIVED WITHIN HOLD TIME(S)
 (EXCLUDES TYPICAL FIELD PARAMETERS)
 DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

896

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Herscher Custody / HES ADDRESS 501 N Main St CITY Herscher, IL 60941 STATE CONTACT PERSON Larry Hoberg		P.O. NUMBER SCHOOL NAME EMAIL PHONE NUMBER 815/426-6888 SAMPLER (PLEASE PRINT) Larry Hoberg SIGNATURE 		MEANS SHIPPED DATE SHIPPED MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER: BOTTLE TYPE DW		ANALYSIS REQUESTED LEAD 200.8		(FOR LAB USE ONLY) 4 LOGIN # LOGGED BY: LAB PROJ. # TEMPLATE: PROJ. MGR.: KURT STEPPING		DATE/TIME LAST USED	
2 SAMPLE PERSON HAS VOLUNTEERED FOR TEST DATE COLLECTED TIME COLLECTED SAMPLE VOLUME COLLECTED		DATE RESULTS NEEDED RUSH		DATE TIME		DATE TIME		DATE TIME		COMMENTS: (FOR LAB USE ONLY) 8 SAMPLE TEMPERATURE UPON RECEIPT CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIMES (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE 13 °C Y OR N Y OR N Y OR N Y OR N	
3 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH Y/N IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE FAX # IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE TIME		DATE TIME		DATE TIME		DATE TIME		COMMENTS: (FOR LAB USE ONLY) 6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-0.6 °C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.	
4 RELINQUISHED BY: (SIGNATURE) Larry Hoberg DATE TIME		RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) 		DATE TIME		DATE TIME		DATE TIME		DATE TIME	
5 RELINQUISHED BY: (SIGNATURE) DATE TIME		RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) 		DATE TIME		DATE TIME		DATE TIME		DATE TIME	

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

997

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: <u>Herscher Custody / HIS</u> ADDRESS: <u>501 N. Main St</u> CITY: <u>Peoria</u> STATE: <u>IL</u> ZIP: <u>61615</u> CONTACT PERSON: <u>Larry Honberg</u>		P.O. NUMBER: _____ SCHOOL NAME: _____ EMAIL: _____ PHONE NUMBER: <u>8157426-888</u> SAMPLER (PLEASE PRINT): <u>Larry Honberg</u> SAMPLER'S SIGNATURE: <u>[Signature]</u>		MEANS SHIPPED: _____ DATE SHIPPED: _____ MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER: _____		ANALYSIS REQUESTED: <u>LEAD 200.8</u>		(FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
2 SAMPLE DESCRIPTION: _____ ANALYST: _____ DATE COLLECTED: _____ TIME COLLECTED: _____ VOLUME COLLECTED: _____ DATE RESULTS NEEDED: _____ RUSH: <u>NORMAL</u>		DATE COLLECTED: <u>4/5</u> TIME COLLECTED: <u>7:10 AM</u> VOLUME COLLECTED: <u>ml</u> DATE RESULTS NEEDED: _____ RUSH: _____		DATE SHIPPED: _____ MATRIX TYPES: _____ OTHER: _____		ANALYSIS REQUESTED: _____		(FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
3 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____		DATE RESULTS NEEDED: _____ RUSH: _____		MEANS SHIPPED: _____ DATE SHIPPED: _____		ANALYSIS REQUESTED: _____		(FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
4 RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____ RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____ RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____		RECEIVED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____ RECEIVED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____ RECEIVED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____		MEANS SHIPPED: _____ DATE SHIPPED: _____		ANALYSIS REQUESTED: _____		(FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
5 DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____		DATE RESULTS NEEDED: _____ RUSH: _____		MEANS SHIPPED: _____ DATE SHIPPED: _____		ANALYSIS REQUESTED: _____		(FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
6 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____		DATE RESULTS NEEDED: _____ RUSH: _____		MEANS SHIPPED: _____ DATE SHIPPED: _____		ANALYSIS REQUESTED: _____		(FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
7 RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____ RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____ RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____		RECEIVED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____ RECEIVED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____ RECEIVED BY: (SIGNATURE) <u>[Signature]</u> DATE: _____ TIME: _____		MEANS SHIPPED: _____ DATE SHIPPED: _____		ANALYSIS REQUESTED: _____		(FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
8 COMMENTS: (FOR LAB USE ONLY) CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE		DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____ DATE: _____ TIME: _____		MEANS SHIPPED: _____ DATE SHIPPED: _____		ANALYSIS REQUESTED: _____		(FOR LAB USE ONLY) LOGIN # _____ LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

November 10, 2017

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **10/27/17 9:35 am** and logged in under work order **7104759**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7104759-01
Name: South Office DF 1st
Matrix: Drinking Water - Regular Sample

Sampled: 10/26/17 06:18
Received: 10/27/17 09:35

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.66	ug/L		11/08/17 11:57	11/08/17 16:51	KMC	EPA 200.8

Sample: 7104759-02
Name: South Office DF 2nd
Matrix: Drinking Water - Regular Sample

Sampled: 10/26/17 06:18
Received: 10/27/17 09:35

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	9.91	ug/L		11/08/17 11:57	11/08/17 17:01	KMC	EPA 200.8

Sample: 7104759-03
Name: SW Hall 2nd Fl 1st
Matrix: Drinking Water - Regular Sample

Sampled: 10/26/17 06:22
Received: 10/27/17 09:35

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.56	ug/L		11/08/17 11:57	11/08/17 17:03	KMC	EPA 200.8

Sample: 7104759-04
Name: SW Hall 2nd Fl 2nd
Matrix: Drinking Water - Regular Sample

Sampled: 10/26/17 06:22
Received: 10/27/17 09:35

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.62	ug/L		11/08/17 11:57	11/08/17 17:04	KMC	EPA 200.8

Sample: 7104759-05
Name: NB Gym DF 1st
Matrix: Drinking Water - Regular Sample

Sampled: 10/26/17 06:30
Received: 10/27/17 09:35

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.79	ug/L		11/08/17 11:57	11/08/17 17:05	KMC	EPA 200.8



PDC Laboratories, Inc.
2231 West Altorfer Drive
Peoria, IL 61615
(800) 752-6651

ANALYTICAL RESULTS

Sample: 7104759-06
Name: NB Gym DF 2nd
Matrix: Drinking Water - Regular Sample

Sampled: 10/26/17 06:30
Received: 10/27/17 09:35

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>							
Lead	3.11	ug/L		11/08/17 11:57	11/08/17 17:07	KMC	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



CHAIN OF CUSTODY RECORD

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE # 800-752-6651
 FAX # 309-692-9689

State where samples collected _____

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT) - (SAMPLE ACCEPTANCE POLICY ON REVERSE)

1 CLIENT: <u>Harscher-CUSD#2</u> ADDRESS: <u>501 N. Main St</u> CITY: <u>Peoria</u> STATE: <u>IL</u> ZIP: <u>61604</u> CONTACT PERSON: <u>Larry Henberg</u>		PROJECT NUMBER: _____ P.O. NUMBER: _____ MEANS SHIPPED: _____ DATE SHIPPED: <u>10/26/17</u>		PHONE NUMBER: <u>309-692-6651</u> FAX NUMBER: _____ SAMPLER (PLEASE PRINT): <u>Larry Henberg</u> SAMPLER'S SIGNATURE: <u>[Signature]</u>		ANALYSIS REQUESTED: _____ LOGIN # <u>1104758-6</u> LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: _____	
2 SAMPLE DESCRIPTION AS YOU WANT ON REPORT		DATE COLLECTED: _____ TIME COLLECTED: _____		MATRIX TYPE: _____ BOTTLE COUNT: _____		REMARKS: _____	
<u>South Office DF 6H Tests 1st Draw</u>		<u>10/26 6:18 AM</u>		<u>DW 1</u>		X	
<u>South Office DF 6H Tests 2nd Draw</u>		<u>10/26 6:18 AM</u>		<u>DW 1</u>		X	
<u>SW Hall 2nd Fl DF Tests 1st Draw</u>		<u>10/26 6:21 AM</u>		<u>DW 1</u>		X	
<u>SW Hall 2nd Fl DF Tests 2nd Draw</u>		<u>10/26 6:22 AM</u>		<u>DW 1</u>		X	
<u>N.B. Cyns DF Test 3</u>		<u>10/26 6:30 AM</u>		<u>DW 1</u>		X	
<u>N.B. Cyns DF Test 3</u>		<u>10/26 6:30 AM</u>		<u>DW 1</u>		X	
TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH FEE IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		RUSH RESULTS VIA (PLEASE CIRCLE)		DATE RESULTS NEEDED: _____ E-MAIL: _____		COMMENTS: (FOR LAB USE ONLY)	
5		NORMAL <input checked="" type="radio"/> RUSH <input type="radio"/>		RECEIVED BY: (SIGNATURE) _____		SAMPLE TEMPERATURE UPON RECEIPT: _____ °C CALL UP PROCESS STARTED PRIOR TO RECEIPT: _____ SAMPLE(S) RECEIVED ON ICE: _____ PROPER BOTTLES RECEIVED IN GOOD CONDITION: _____ BOTTLES FILLED WITH ADEQUATE VOLUME: _____ SAMPLES RECEIVED WITHIN HOLD TIME(S): _____ (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE: _____	
7 RELINQUISHED BY: (SIGNATURE) _____		DATE: _____ TIME: _____		RECEIVED BY: (SIGNATURE) _____		DATE: _____ TIME: _____	
RELINQUISHED BY: (SIGNATURE) _____		DATE: _____ TIME: _____		RECEIVED AT LAB BY: (SIGNATURE) _____		DATE: _____ TIME: _____	

Copies: white should accompany samples to PDC Labs. Yellow copy to be retained by the client.



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

May 03, 2017

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **4/21/17 7:30 am** and logged in under work order **7043372**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Kurt Stepping
Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7043372-01
Name: SOUTH OFFICE DF 1ST FL
Alias: 1ST DRAW

Sampled: 04/20/17 04:00
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.68	ug/L		15	05/02/17 13:47	KMC	EPA 200.8

Sample: 7043372-02
Name: SOUTH OFFICE DF 1ST FL
Alias: 2ND DRAW

Sampled: 04/20/17 04:00
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	10.1	ug/L		15	05/02/17 13:48	KMC	EPA 200.8

Sample: 7043372-03
Name: 8104
Alias: 1ST DRAW

Sampled: 04/20/17 04:03
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	28.4	ug/L		**15	05/02/17 13:50	KMC	EPA 200.8

Sample: 7043372-04
Name: 8104
Alias: 2ND DRAW

Sampled: 04/20/17 04:03
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.18	ug/L		15	05/02/17 13:51	KMC	EPA 200.8

Sample: 7043372-05
Name: SO WEST HALL DR 1ST FL
Alias: 1ST DRAW

Sampled: 04/20/17 04:05
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.59	ug/L		15	05/02/17 13:52	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-06
Name: SO WEST HALL DR 1ST FL
Alias: 2ND DRAW

Sampled: 04/20/17 04:05
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.23	ug/L		15	05/02/17 13:53	KMC	EPA 200.8

Sample: 7043372-07
Name: 8102
Alias: 1ST DRAW

Sampled: 04/20/17 04:08
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	65.8	ug/L		**15	05/02/17 13:54	KMC	EPA 200.8

Sample: 7043372-08
Name: 8102
Alias: 2ND DRAW

Sampled: 04/20/17 04:08
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.75	ug/L		15	05/02/17 13:55	KMC	EPA 200.8

Sample: 7043372-09
Name: 8103
Alias: 1ST DRAW

Sampled: 04/20/17 04:12
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	14.5	ug/L		15	05/02/17 14:05	KMC	EPA 200.8

Sample: 7043372-10
Name: 8103
Alias: 2ND DRAW

Sampled: 04/20/17 04:12
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.93	ug/L		15	05/02/17 14:06	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-11
Name: 8101
Alias: 1ST DRAW

Sampled: 04/20/17 04:20
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	94.4	ug/L		**15	05/02/17 14:07	KMC	EPA 200.8

Sample: 7043372-12
Name: 8101
Alias: 2ND DRAW

Sampled: 04/20/17 04:20
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	19.4	ug/L		**15	05/02/17 14:08	KMC	EPA 200.8

Sample: 7043372-13
Name: 8100
Alias: 1ST DRAW

Sampled: 04/20/17 04:15
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	435	ug/L		**15	05/02/17 14:09	KMC	EPA 200.8

Sample: 7043372-14
Name: 8100
Alias: 2ND DRAW

Sampled: 04/20/17 04:15
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	13.5	ug/L		15	05/02/17 14:10	KMC	EPA 200.8

Sample: 7043372-15
Name: 8114
Alias: 1ST DRAW

Sampled: 04/20/17 04:25
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.90	ug/L		15	05/02/17 14:11	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-16
Name: 8114
Alias: 2ND DRAW

Sampled: 04/20/17 04:25
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:12	KMC	EPA 200.8

Sample: 7043372-17
Name: 8116
Alias: 1ST DRAW

Sampled: 04/20/17 04:30
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.61	ug/L		15	05/02/17 14:22	KMC	EPA 200.8

Sample: 7043372-18
Name: 8116
Alias: 2ND DRAW

Sampled: 04/20/17 04:30
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:23	KMC	EPA 200.8

Sample: 7043372-19
Name: 8118
Alias: 1ST DRAW

Sampled: 04/20/17 04:35
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.29	ug/L		15	05/02/17 14:24	KMC	EPA 200.8

Sample: 7043372-20
Name: 8118
Alias: 2ND DRAW

Sampled: 04/20/17 04:35
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.00	ug/L		15	05/02/17 14:25	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-21
Name: SO E 1ST FL DF
Alias: 1ST DRAW

Sampled: 04/20/17 04:35
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:26	KMC	EPA 200.8

Sample: 7043372-22
Name: SO E 1ST FL DF
Alias: 2ND DRAW

Sampled: 04/20/17 04:35
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:28	KMC	EPA 200.8

Sample: 7043372-23
Name: KIT N
Alias: 1ST DRAW

Sampled: 04/20/17 04:42
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.91	ug/L		15	05/02/17 14:29	KMC	EPA 200.8

Sample: 7043372-24
Name: KIT N
Alias: 2ND DRAW

Sampled: 04/20/17 04:42
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:30	KMC	EPA 200.8

Sample: 7043372-25
Name: KIT M
Alias: 1ST DRAW

Sampled: 04/20/17 04:44
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:39	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-26
Name: KIT M
Alias: 2ND DRAW

Sampled: 04/20/17 04:44
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:40	KMC	EPA 200.8

Sample: 7043372-27
Name: KIT S
Alias: 1ST DRAW

Sampled: 04/20/17 04:46
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:41	KMC	EPA 200.8

Sample: 7043372-28
Name: KIT S
Alias: 2ND DRAW

Sampled: 04/20/17 04:46
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:43	KMC	EPA 200.8

Sample: 7043372-29
Name: S E 2ND FL DF
Alias: 1ST DRAW

Sampled: 04/20/17 04:55
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:44	KMC	EPA 200.8

Sample: 7043372-30
Name: S E 2ND FL DF
Alias: 2ND DRAW

Sampled: 04/20/17 04:55
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:45	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-31
Name: 8214
Alias: 1ST DRAW

Sampled: 04/20/17 05:00
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.97	ug/L		15	05/02/17 14:46	KMC	EPA 200.8

Sample: 7043372-32
Name: 8214
Alias: 2ND DRAW

Sampled: 04/20/17 05:00
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	7.93	ug/L		15	05/02/17 14:47	KMC	EPA 200.8

Sample: 7043372-33
Name: 8212
Alias: 1ST DRAW

Sampled: 04/20/17 05:05
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	7.27	ug/L		15	05/02/17 14:57	KMC	EPA 200.8

Sample: 7043372-34
Name: 8212
Alias: 2ND DRAW

Sampled: 04/20/17 05:05
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 14:58	KMC	EPA 200.8

Sample: 7043372-35
Name: 8208
Alias: 1ST DRAW

Sampled: 04/20/17 05:10
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.28	ug/L		15	05/02/17 14:59	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-36
Name: 8208
Alias: 2ND DRAW

Sampled: 04/20/17 05:10
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 15:00	KMC	EPA 200.8

Sample: 7043372-37
Name: 8204
Alias: 1ST DRAW

Sampled: 04/20/17 05:15
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	41.1	ug/L		**15	05/02/17 15:01	KMC	EPA 200.8

Sample: 7043372-38
Name: 8204
Alias: 2ND DRAW

Sampled: 04/20/17 05:15
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.01	ug/L		15	05/02/17 15:02	KMC	EPA 200.8

Sample: 7043372-39
Name: S W HALL 2ND FL DF
Alias: 1ST DRAW

Sampled: 04/20/17 05:20
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.21	ug/L		15	05/02/17 15:03	KMC	EPA 200.8

Sample: 7043372-40
Name: S W HALL 2ND FL DF
Alias: 2ND DRAW

Sampled: 04/20/17 05:20
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	16.5	ug/L		**15	05/02/17 15:04	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-41
Name: 8202
Alias: 1ST DRAW

Sampled: 04/20/17 05:25
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	224	ug/L		**15	05/02/17 15:14	KMC	EPA 200.8

Sample: 7043372-42
Name: 8202
Alias: 2ND DRAW

Sampled: 04/20/17 05:25
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	7.69	ug/L		15	05/02/17 15:15	KMC	EPA 200.8

Sample: 7043372-43
Name: 8203
Alias: 1ST DRAW

Sampled: 04/20/17 05:30
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	39.7	ug/L		**15	05/02/17 15:16	KMC	EPA 200.8

Sample: 7043372-44
Name: 8203
Alias: 2ND DRAW

Sampled: 04/20/17 05:30
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.05	ug/L		15	05/02/17 15:17	KMC	EPA 200.8

Sample: 7043372-45
Name: 8201
Alias: 1ST DRAW

Sampled: 04/20/17 05:35
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	156	ug/L		**15	05/02/17 15:18	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-46
Name: 8201
Alias: 2ND DRAW

Sampled: 04/20/17 05:35
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	69.6	ug/L		**15	05/02/17 15:19	KMC	EPA 200.8

Sample: 7043372-47
Name: 8200
Alias: 1ST DRAW

Sampled: 04/20/17 05:40
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	24.2	ug/L		**15	05/02/17 15:21	KMC	EPA 200.8

Sample: 7043372-48
Name: 8200
Alias: 2ND DRAW

Sampled: 04/20/17 05:40
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.38	ug/L		15	05/02/17 15:22	KMC	EPA 200.8

Sample: 7043372-49
Name: N CUST DF
Alias: 1ST DRAW

Sampled: 04/20/17 05:50
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 15:31	KMC	EPA 200.8

Sample: 7043372-50
Name: N CUST DF
Alias: 2ND DRAW

Sampled: 04/20/17 05:50
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 15:32	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-51
Name: N S GYM DF
Alias: 1ST DRAW

Sampled: 04/20/17 05:55
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		15	05/02/17 15:33	KMC	EPA 200.8

Sample: 7043372-52
Name: N S GYM DF
Alias: 2ND DRAW

Sampled: 04/20/17 05:55
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.22	ug/L		15	05/02/17 15:35	KMC	EPA 200.8

Sample: 7043372-53
Name: N N DF
Alias: 1ST DRAW

Sampled: 04/20/17 06:00
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.25	ug/L		15	05/02/17 15:36	KMC	EPA 200.8

Sample: 7043372-54
Name: N N DF
Alias: 2ND DRAW

Sampled: 04/20/17 06:00
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.97	ug/L		15	05/02/17 15:37	KMC	EPA 200.8

Sample: 7043372-55
Name: N B GYM DF
Alias: 1ST DRAW

Sampled: 04/20/17 06:05
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.55	ug/L		15	05/03/17 08:30	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7043372-56
Name: N B GYM DF
Alias: 2ND DRAW

Sampled: 04/20/17 06:05
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	5.38	ug/L		15	05/02/17 15:39	KMC	EPA 200.8

Sample: 7043372-57
Name: N ORCH DF
Alias: 1ST DRAW

Sampled: 04/20/17 06:10
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	4.19	ug/L		15	05/02/17 15:49	KMC	EPA 200.8

Sample: 7043372-58
Name: N ORCH DF
Alias: 2ND DRAW

Sampled: 04/20/17 06:10
Received: 04/21/17 07:30
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.46	ug/L		15	05/02/17 15:50	KMC	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

** Indicates lab result exceeds a monitoring limit. Monitoring limits are either client permit limits or client requested action levels.

Certifications

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT		SCHOOL NAME		MEANS SHIPPED		ANALYSIS REQUESTED		(FOR LAB USE ONLY)	
1	Herscher CUSD #2	P.O. NUMBER	SCHOOL NAME	PHONE NUMBER	EMAIL	DATE SHIPPED	DATE SHIPPED	3	4
ADDRESS		SAMPLER (PLEASE PRINT)		SAMPLER'S SIGNATURE		MATRIX TYPES:		LOGIN #	LOGGED BY:
501 N Main St		Larry Houbert		Larry Houbert		WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER:		7043372-58	JKH
CITY		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED		LAB PROJ. #	TEMPLATE:
Herscher, IL 60941		4/20		4:00 AM		ml			PROJ. MGR.: KURT STEPPING
CONTACT PERSON		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED		DATE/TIME LAST USED	
Larry Houbert		4/20		4:03 AM		ml			
2		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
South Office DF/1st fl / 1st draw		4/20		4:03 AM		ml			
South Office DF/1st fl / 2nd draw		4/20		4:05 AM		ml			
8104 / 1st draw		4/20		4:08 AM		ml			
8104 / 2nd draw		4/20		4:08 AM		ml			
So/West Hall/DF/1st fl / 1st draw		4/20		4:12 AM		ml			
So/West Hall/DF/1st fl / 2nd draw		4/20		4:12 AM		ml			
8102 / 1st draw		4/20		4:12 AM		ml			
8102 / 2nd draw		4/20		4:12 AM		ml			
8103 / 1st draw		4/20		4:12 AM		ml			
8103 / 2nd draw		4/20		4:12 AM		ml			
5		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
TURNAROUND TIME REQUESTED (PLEASE CIRCLE)		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
(RUSH FEE IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		4/20		7:00 AM		ml			
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
NORMAL RUSH		4/20		7:00 AM		ml			
FAX # IF DIFFERENT FROM ABOVE:		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
PHONE # IF DIFFERENT FROM ABOVE:		4/20		7:00 AM		ml			
7		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
RELINQUISHED BY: (SIGNATURE)		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
Larry Houbert		4/20		7:00 AM		ml			
RELINQUISHED BY: (SIGNATURE)		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
6		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
The sample temperature will be measured upon receipt at the lab. By initialing this area you request that the lab notify you. Before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0°C. By not initialing this area you allow the lab to proceed with analytical testing regardless of the sample temperature.		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
8		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
COMMENTS: (FOR LAB USE ONLY)		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
		4/20		7:30		ml			
SAMPLE TEMPERATURE UPON RECEIPT		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
20 °C		4/20		7:30		ml			
CHILL PROCESS STARTED PRIOR TO RECEIPT		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED			
SAMPLE(S) RECEIVED ON ICE									
BOTTLES FILLED WITH ADEQUATE VOLUME									
SAMPLES RECEIVED WITHIN HOLD TIME(S)									
(EXCLUDES TYPICAL FIELD PARAMETERS)									
DATE AND TIME TAKEN FROM SAMPLE BOTTLE									

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 762-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

#2

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT		SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
CLIENT	Herscher CUSD#2	SCHOOL NAME		MEANS SHIPPED		ANALYSIS REQUESTED		LOGGED BY:	
ADDRESS	501 N Main St	PHONE NUMBER		DATE SHIPPED				LAB PROJ. #	
CITY	Herscher, IL 60941	SAMPLER (PLEASE PRINT)	Larry Houbert	MATRIX TYPES:				TEMPLATE:	
STATE	IL	SAMPLER'S SIGNATURE	<i>Larry Houbert</i>	WW-WASTEWATER				PROJ. MGR.: KURT STEPPING	
ZIP	60941			GW-GROUND WATER					
CONTACT PERSON	Larry Houbert	DATE	TIME	OTHER:					
		DATE	TIME	MATRIX TYPE					
		DATE	TIME	MATRIX TYPE					
8101	1st draw	4/20	4:20 AM	DW	1	X	LEAD 2008		
8101	2nd draw	4/20	4:20 AM	DW	1	X			
8100	1st draw	4/20	4:15 AM	DW	1	X			
8100	2nd draw	4/20	4:15 AM	DW	1	X			
8114	1st draw	4/20	4:25 AM	DW	1	X			
8114	2nd draw	4/20	4:25 AM	DW	1	X			
8116	1st draw	4/20	4:30 AM	DW	1	X			
8116	2nd draw	4/20	4:30 AM	DW	1	X			
8118	1st draw	4/20	4:35 AM	DW	1	X			
8118	2nd draw	4/20	4:35 AM	DW	1	X			

6	TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)	NORMAL	RUSH
	RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE		
	FAX # IF DIFFERENT FROM ABOVE	PHONE # IF DIFFERENT FROM ABOVE	

7	RELINQUISHED BY: (SIGNATURE)	DATE	TIME
	<i>Larry Houbert</i>	4/20	7:00 AM
	RELINQUISHED BY: (SIGNATURE)	DATE	TIME
	RELINQUISHED BY: (SIGNATURE)	DATE	TIME

8	COMMENTS: (FOR LAB USE ONLY)
	SAMPLE TEMPERATURE UPON RECEIPT
	CHILL PROCESS STARTED PRIOR TO RECEIPT
	SAMPLE(S) RECEIVED ON ICE
	PROPER BOTTLES RECEIVED IN GOOD CONDITION
	BOTTLES FILLED WITH ADEQUATE VOLUME
	SAMPLES RECEIVED WITHIN HOLD TIME(S)
	(EXCLUDES TYPICAL FIELD PARAMETERS)
	DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
ILLINOIS SCHOOLS LEAD TESTING

44

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT		P.O. NUMBER		SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
Herscher CASD #2						DATE SHIPPED		LEAD 2008		LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
ADDRESS: 501 N Main St		PHONE NUMBER		EMAIL		DATE SHIPPED					
CITY STATE ZIP		SAMPLER (PLEASE PRINT)		SAMPLER'S SIGNATURE		MATRIX TYPES: WK- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WSL- SLUDGE NAS- SOLID LCHT- LEACHATE OTHER: _____					
CONTACT PERSON		DATE COLLECTED		TIME COLLECTED		SAMPLE VOLUME COLLECTED					
Larry Homborg		4/20		5:00 AM		ml		DW		DATE/TIME LAST USED	
		4/20		5:00 AM		ml		DW			
		4/20		5:05 AM		ml		DW			
		4/20		5:05 AM		ml		DW			
		4/20		5:10 AM		ml		DW			
		4/20		5:10 AM		ml		DW			
		4/20		5:15 AM		ml		DW			
		4/20		5:15 AM		ml		DW			
8214 / 1st draw											
8214 / 2nd draw											
8212 / 1st draw											
8212 / 2nd draw											
8208 / 1st draw											
8208 / 2nd draw											
S1#2 / 2nd F1 / DF / 1st draw											
S1#2 / 2nd F1 / DF / 2nd draw											
8204 / 1st draw											
8204 / 2nd draw											

6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-8.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH FAX IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED	
NORMAL RUSH			
RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE			
FAX # IF DIFFERENT FROM ABOVE: _____ PHONE # IF DIFFERENT FROM ABOVE: _____			

7 RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE	
<i>[Signature]</i>		4/20		<i>[Signature]</i>		4/21/17	
		TIME 7:05 AM				TIME 7:30	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE	
				<i>[Signature]</i>			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE	
				<i>[Signature]</i>			

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: 20 °C

CHILL PROCESS STARTED PRIOR TO RECEIPT. Y OR N

SAMPLE(S) RECEIVED ON ICE Y OR N

PROPER BOTTLES RECEIVED IN GOOD CONDITION Y OR N

BOTTLES FILLED WITH ADEQUATE VOLUME Y OR N

SAMPLES RECEIVED WITHIN HOLD TIME(S) Y OR N

(EXCLUDES TYPICAL FIELD PARAMETERS)



DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 762-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

#15

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT		P.O. NUMBER		SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
Herscher Caso #2								LEAD 200.8		LOGGED BY: _____ LAB PROJ. # _____ TEMPLATE: _____ PROJ. MGR.: KURT STEPPING	
ADDRESS		PHONE NUMBER		EMAIL		DATE SHIPPED					
501 N Main St											
CITY		SAMPLER (PLEASE PRINT)		MATRIX TYPES:		DATE SHIPPED					
Herscher, IL 60941		Larry Houbers		WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE MAS- SOLID LCHT- LEACHATE							
CONTACT PERSON		SAMPLER'S SIGNATURE		DATE COLLECTED		TIME COLLECTED		DATE RESULTS NEEDED			
Larry Houbers		<i>Larry Houbers</i>									
2 SAMPLE DESCRIPTION		DATE COLLECTED		TIME COLLECTED		SAMPLER'S SIGNATURE		DATE RESULTS NEEDED			
S/W Hall / 2nd fl / DF / 1st draw		4/20		5:20 AM		mi					
S/W Hall / 2nd fl / DF / 2nd draw		4/20		5:20 AM		mi					
8202 / 1st draw		4/20		5:25 AM		mi					
8202 / 2nd draw		4/20		5:25 AM		mi					
8203 / 1st draw		4/20		5:30 AM		mi					
8203 / 2nd draw		4/20		5:30 AM		mi					
8201 / 1st draw		4/20		5:35 AM		mi					
8201 / 2nd draw		4/20		5:35 AM		mi					
8200 / 1st draw		4/20		5:40 AM		mi					
8200 / 2nd draw		4/20		5:40 AM		mi					
NT 2nd draw		4/20		5:40 AM							
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE PHONE # IF DIFFERENT FROM ABOVE: _____										6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0-1-6.0°C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.	
7 RELINQUISHED BY: (SIGNATURE) <i>Larry Houbers</i>		DATE 4/20 TIME 7:00 AM		RECEIVED BY: (SIGNATURE) 		DATE TIME		RECEIVED BY: (SIGNATURE) 		DATE TIME	
8 COMMENTS: (FOR LAB USE ONLY)		SAMPLE TEMPERATURE UPON RECEIPT 20 °C		CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE		Y OR N Y OR N Y OR N Y OR N					

PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6651 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING
 #6

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT		SCHOOL NAME		MEANS SHIPPED		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY)	
Herscher CUSD #2		Herscher, IL 60941		Larry Houberg		LEAD 200.8		LOGGED BY: LAB PROJ. # TEMPLATE: PROJ. MGR.: KURT STEPPING	
501 N Main St		Larry Houberg		DATE SHIPPED					
CONTACT PERSON		SAMPLER'S SIGNATURE		MATRIX TYPES:					
Larry Houberg		<i>[Signature]</i>		WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE MAS- SOLID LCHT- LEACHATE OTHER:					
2 SAMPLE DESCRIPTION (PLEASE PRINT) AND YOU WANT ON REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE VOLUME COLLECTED	MATRIX TYPE	BOTTLE COUNT	COUNTY	DATE/TIME LAST USED	
N/Cust/DF/1st draw		4/20	5:50 AM	ml	DW	1		X	
N/Cust/DF/2nd draw		4/20	5:50 AM	ml	DW	1		X	
N/S Gym/DF/1st draw		4/20	5:55 AM	ml	DW	1		X	
N/S Gym/DF/2nd draw		4/20	5:55 AM	ml	DW	1		X	
N/N DF/1st draw		4/20	6:00 AM	ml	DW	1		X	
N/N DF/2nd draw		4/20	6:00 AM	ml	DW	1		X	
N/B Gym/DF/1st draw		4/20	6:05 PM	ml	DW	1		X	
N/B Gym/DF/2nd draw		4/20	6:05 PM	ml	DW	1		X	
N/Orch DF/1st draw		4/20	6:10 AM	ml	DW	1		X	
N/Orch DF/2nd draw		4/20	6:10 AM	ml	DW	1		X	
N/Orch DF/1st draw		4/20	6:10 AM						

6 The sample temperature will be measured upon receipt at the lab. By initiating this area you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0.1-6.0° C. By not initiating this area you allow the lab to proceed with analytical testing regardless of the sample temperature.

7 RELINQUISHED BY: (SIGNATURE) DATE 4/20 TIME 7:00 AM

8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT 20 °C

9 CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

January 08, 2018

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **12/22/17 9:50 am** and logged in under work order **7123855**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7123855-01
Name: LMS N 2nd FL DF South End 1st
Matrix: Drinking Water - Regular Sample

Sampled: 12/20/17 06:20
Received: 12/22/17 09:50

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.39	ug/L		01/08/18 07:42	01/08/18 13:20	KMC	EPA 200.8

Sample: 7123855-02
Name: LMS N 2nd FL DF South End 2nd
Matrix: Drinking Water - Regular Sample

Sampled: 12/20/17 06:20
Received: 12/22/17 09:50

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	6.23	ug/L		01/08/18 07:42	01/08/18 13:28	KMC	EPA 200.8

Sample: 7123855-03
Name: LMS N Kit North Sink 1st
Matrix: Drinking Water - Regular Sample

Sampled: 12/20/17 06:25
Received: 12/22/17 09:50

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.65	ug/L		01/08/18 07:42	01/08/18 13:29	KMC	EPA 200.8

Sample: 7123855-04
Name: LMS N Kit North Sink 2nd
Matrix: Drinking Water - Regular Sample

Sampled: 12/20/17 06:25
Received: 12/22/17 09:50

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	2.09	ug/L		01/08/18 07:42	01/08/18 13:30	KMC	EPA 200.8

Sample: 7123855-05
Name: LMS N Kit East Sink 1st
Matrix: Drinking Water - Regular Sample

Sampled: 12/20/17 06:27
Received: 12/22/17 09:50

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	15.3	ug/L		01/08/18 07:42	01/08/18 13:31	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 7123855-06
Name: LMS N Kit East Sink 2nd
Matrix: Drinking Water - Regular Sample

Sampled: 12/20/17 06:27

Received: 12/22/17 09:50

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>							
Lead	< 1.00	ug/L		01/08/18 07:42	01/08/18 13:33	KMC	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager





PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

September 21, 2018

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **9/12/18 10:00 am** and logged in under work order **8093200**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Kurt Stepping
Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 8093200-01
Name: LMS/N/2NDFL/NDF/1ST DRAW
Matrix: Drinking Water - Regular Sample

Sampled: 09/11/18 06:10
Received: 09/12/18 10:00

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	3.80	ug/L		09/21/18 05:57	09/21/18 08:32	JMW	EPA 200.8

Sample: 8093200-02
Name: LMS/N/2NDFL/NDF/2ND DRAW
Matrix: Drinking Water - Regular Sample

Sampled: 09/11/18 06:10
Received: 09/12/18 10:00

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		09/21/18 05:57	09/21/18 08:34	JMW	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPIL - Springfield, IL

NELAP/NELAC accreditation through the Illinois EPA, Lab No. 100323

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 PHONE: (800) 752-6661 FAX: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: Herscher CUSD #2 ADDRESS: 501 N. Main St CITY: Herscher, IL 60941 CONTACT PERSON: Larry Howberg		SCHOOL NAME: Herscher CUSD #2 P.O. NUMBER: 815/426-6869 PHONE NUMBER: 815/426-6869 EMAIL: Larry Howberg		MEANS SHIPPED: 815/426-6869 Howberg@HerscherCUSD.org DATE SHIPPED:		ANALYSIS REQUESTED: LEAD 2008		(FOR LAB USE ONLY) LOGIN # 8093200-2 LAB PROJ. # TEMPLATE: PROJ. MGR.: KURT STEPPING	
2 SAMPLE DESCRIPTION AS YOUR WANT ON REPORT: LMS/N/2ndA/NDF/1st draw LMS/N/2ndA/NDF/2nd draw		QUANTITY COLLECTED: 9/11 6:10 AM TIME COLLECTED:		MATRIX TYPES: <input type="checkbox"/> WW-WASTEWATER <input type="checkbox"/> DW-DRINKING WATER <input type="checkbox"/> GW-GROUND WATER <input type="checkbox"/> WWS-WINDGE <input type="checkbox"/> MAS-SOLID <input type="checkbox"/> LCHT-LEACHATE OTHER:		DATE/TIME LAST USED		LOGGED BY: LAB PROJ. # TEMPLATE: PROJ. MGR.: KURT STEPPING	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) RUSH (RUSH TAT IS SUBJECT TO PDC LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE 815/426-6869 PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED:		SAMPLE VOLUME COLLECTED:		SAMPLE TEMPERATURE UPON RECEIPT: 22 °C CHILL PROCESS STARTED PRIOR TO RECEIPT: Y SAMPLE(S) RECEIVED ON ICE: Y BOTTLES FILLED WITH ADEQUATE VOLUME: Y BOTTLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS): Y DATE AND TIME TAKEN FROM SAMPLE BOTTLE:		COMMENTS: (FOR LAB USE ONLY)	
7 RELINQUISHED BY: (SIGNATURE) Larry Howberg DATE: 9/11 TIME: 7:50 AM		RECEIVED BY: (SIGNATURE) [Signature] DATE:		RECEIVED BY: (SIGNATURE) [Signature] DATE:		RECEIVED BY: (SIGNATURE) [Signature] DATE:		RECEIVED BY: (SIGNATURE) [Signature] DATE:	



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

December 13, 2017

Larry Houberg
Herscher CUSD #2
501 N Main St
Herscher, IL 60941

Dear Larry Houberg:

Please find enclosed the analytical results for the sample(s) the laboratory received on **11/30/17 7:15 am** and logged in under work order **7114530**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7114530-01
Name: South Office DF 1st Fl 1st Draw
Matrix: Drinking Water - Regular Sample

Sampled: 11/29/17 05:50
Received: 11/30/17 07:15

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.65	ug/L		15	12/12/17 13:46	KMC	EPA 200.8

Sample: 7114530-02
Name: South Office DF 1st Fl 2nd Draw
Matrix: Drinking Water - Regular Sample

Sampled: 11/29/17 05:50
Received: 11/30/17 07:15

Parameter	Result	Unit	Qualifier	MCL	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.33	ug/L		15	12/12/17 13:47	KMC	EPA 200.8



NOTES

Specific method revisions used for analysis are available upon request.

** Indicates lab result exceeds a monitoring limit. Monitoring limits are either client permit limits or client requested action levels.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager

